



Factory Certification Pull-out Test Nr. 243105



Date : 08-01-2024
Location : Adit Factory 1
Product : Adit HSR
Number of Tests : 8
Sizes : M12x60, M16x80,
M20x90, M24x100.
Tester : Eng. W. Huang
Number of Pages : 2


Graphics of load-displacement of the pull-out tests



1. Pull-Out Test of Adit HSR M12x60



2. Pull-Out Test of Adit HSR M16x80



3. Pull-Out Test of Adit HSR M20x90



4. Pull-Out Test of Adit HSR M24x100



Pull-out Load Tests Results

Product	Size	Breaking Load (kN)
Adit HSR	M12x60	46.0
	M16x80	66.5
	M20x90	90.2
	M24x100	106.8

Signature / Stamp :




Date : 08-01-2024